



ORIGINAL PERMIT APPLICANT(S)

SISTERS 3 LLLP (SHAHER, STANLEY E.)

APPROVED WELL LOCATION

Water Division: 1 Water District: 65
Designated Basin: NORTHERN HIGH PLAINS
Management District: CENTRAL YUMA
County: YUMA
Parcel Name: N/A
Physical Address: N/A

NW 1/4 SW 1/4 Section 30 Township 1.0 N Range 42.0 W Sixth P.M.

UTM COORDINATES (Meters, Zone:13, NAD83)

Easting: 746655.2 Northing: 4434120.5

PERMIT TO USE AN EXISTING WELL

ISSUANCE OF THIS PERMIT DOES NOT CONFER A WATER RIGHT

CONDITIONS OF APPROVAL

- 1) This well shall be used in such a way as to cause no material injury to existing water rights. The issuance of this permit does not ensure that no injury will occur to another vested water right or preclude another owner of a vested water right from seeking relief in a civil court action.
- 2) The construction of this well shall be in compliance with the Water Well Construction Rules 2 CCR 402-2, unless approval of a variance has been granted by the State Board of Examiners of Water Well Construction and Pump Installation Contractors in accordance with Rule 18.
- 3) Approved pursuant to CRS 37-90-105 for a change of use of an existing well, constructed under Permit no. 15415-FPR, on a tract of land of 44.5 acres described as the NW1/4 of the SW1/4 and 150 ft. of the northerly portion of the SW1/4 of the SW1/4 of Section 30, Township 1 North, Range 42 West of the Sixth P.M., Yuma County.
- 4) Water from this well may be used for domestic purposes inside 2 single family dwellings, and the watering of the owner's own large non-commercial domestic animals.
- 5) The irrigated area shall not exceed 1 acre of lawn and garden.
- 6) Water from this well may be used for the watering of livestock on range and pasture.
- 7) The pumping rate of this well shall not exceed 50 GPM.
- 8) The annual withdrawal of ground water from this well shall not exceed 5 acre-feet.
- 9) Production is limited to the Ogallala aquifer. Plain casing must be installed and grouted to prevent diversion of water from other zones.
- 10) This well shall be constructed within 300 feet of the location specified on this permit.
- 11) Prior to use of this well under this permit, the well must be modified as follows and evidence of completion of the work submitted to the State Engineer. A liner casing no larger than six inches in diameter shall be installed inside the existing casing of this well. The liner casing shall be steel casing in the interval required by the Water Well Construction Rules, may be PVC casing below the steel cased interval, shall be grouted in the intervals specified for new wells in the Water Well Construction Rules, and shall be fitted with a standard sanitary well seal.
- 12) Issuance of this permit cancels permit no. 15415-FPR, which replaced permit no. 15415-FP.

NOTE: This well is located within the Central Yuma Ground Water Management District where local District Rules apply which may further limit the withdrawal and use of designated ground water as authorized under this permit.

Issued By SHANNON PORTER

Date Issued: 12/13/2018

Expiration Date: 12/13/2020